



CERTIFICATE

Issued Date: Dec. 20, 2007

Report No.: 07C195R-ITCEP07V03

This is to certify that the following designated product

Product : HMI (Human Machine Interface)
Trade Name : EasyView/WeinView
Model Number : MT612X, MT8121X
Company Name : Weintek Labs., Inc.

This product, which has been issued the test report listed as above in Quietek Laboratory, is based on a single evaluation of one sample and confirmed to comply with the requirements of the following EMC standard.

EN 55022: 1998+A1: 2000+A2: 2003 **EN 55024: 1998+A1: 2001+A2: 2003**
IEC 61000-4-2 Edition 1.2: 2001-04
IEC 61000-4-3: 2002+A1: 2002
IEC 61000-4-4: 2004
IEC 61000-4-5 Edition 1.1: 2001-04
IEC 61000-4-6 Edition 2.1: 2004-11
IEC 61000-4-8 Edition 1.1: 2001-03

TEST LABORATORY

Vincent Lin / Deputy Manager



Test Report

Product Name : HMI(Human Machine Interface)

Model No. : MT612X, MT8121X

Applicant : Weintek Labs., Inc.

Address : 3F, No. 910, Chung Cheng Rd, Chung
Ho City, Taipei, Taiwan 235.

Date of Receipt : 2007/12/12

Issued Date : 2007/12/20

Report No. : 07C195R-ITCEP07V03

The test results relate only to the samples tested.

The test results shown in the test report are traceable to the national/international standard through the calibration of the equipment and evaluated measurement uncertainty herein.

This report must not be used to claim product endorsement by TAF, NVLAP or any agency of the Government.

The test report shall not be reproduced except in full without the written approval of QuieTek Corporation.



Declaration of Conformity

The following product is herewith confirmed to comply with the requirements set out in the Council Directive on the Approximation of the laws of the Member States relating to Electromagnetic Compatibility Directive (2004/108/EC). The listed standards as below were applied:

The following Equipment:

Product : HMI(Human Machine Interface)
Trade Name : EasyView/WeinView
Model Number : MT612X, MT8121X

This product is herewith confirmed to comply with the requirements set out in the Council Directive on the Approximation of the laws of the Member States relating to Electromagnetic Compatibility Directive (2004/108/EC). For the evaluation regarding EMC, the following standards were applied:

RFI Emission:

EN 55022:1998+A1:2000+A2:2003 Class A : Product family standard

Immunity:

EN 55024:1998+A1:2001+A2:2003 : Product family standard

The following importer/manufacture is responsible for this declaration:

Company Name :

Company Address :

Telephone :

Facsimile :

Person is responsible for marking this declaration:

Name (Full Name)

Position/ Title

Date

Legal Signature

CE
Statement of Conformity

This certifies that the following designated product:

Product : HMI(Human Machine Interface)
Trade Name : EasyView/WeinView
Model Number : MT612X, MT8121X
Company Name : Weintek Labs., Inc.

This product is herewith confirmed to comply with the requirements set out in the Council Directive on the Approximation of the laws of the Member States relating to Electromagnetic Compatibility Directive (2004/108/EC). For the evaluation regarding EMC, the following standards were applied:

RFI Emission:

EN 55022:1998+A1:2000+A2:2003 Class A : Product family standard

Immunity:

EN 55024:1998+A1:2001+A2:2003 : Product family standard



Testing Laboratory

0914

TEST LABORATORY

Vincent Lin / Deputy Manager

The verification is based on a single evaluation of one sample of above-mentioned products. It does not imply an assessment of the whole production and does not permit the use of the test lab. Logo.

Test Report Certification

Issued Date : 2007/12/20

Report No. : 07C195R-ITCEP07V03



Product Name : HMI(Human Machine Interface)

Applicant : Weintek Labs., Inc.

Address : 3F, No. 910, Chung Cheng Rd, Chung Ho City, Taipei,
Taiwan 235.

Manufacturer : Weintek Labs., Inc.

Model No. : MT612X, MT8121X

Rated Voltage : AC 230 V / 50 Hz

EUT Voltage : DC 24V

Trade Name : EasyView/WeinView

Applicable Standard : EN 55022: 1998+A1: 2000+A2: 2003 Class A
EN 55024: 1998+A1: 2001+A2: 2003

Test Result : Complied

Performed Location : Quietek Corporation (Linkou Laboratory)
No.5-22,Ruei-Shu Valley, Ruei-Ping Tsuen Lin Kuo
Shiang, Taipei, 244 Taiwan, R.O.C.
TEL:+866-2-8601-3788 / FAX:+886-2-8601-3789

Documented By : Rita Huang
(Engineering Adm. Specialist /
Rita Huang)

Reviewed By : Kent Chen
(Engineer / Kent Chen)

Approved By : Vincent Lin
(Deputy Manager / Vincent Lin)

Laboratory Information

We , **Quietek Corporation**, are an independent EMC and safety consultancy that was established the whole facility in our laboratories. The test facility has been accredited/accepted (audited or listed) by the following related bodies in compliance with ISO 17025, EN 45001 and specified testing scopes:

Taiwan R.O.C.	:	BSMI, NCC, TAF
Germany	:	TUV Rheinland
Norway	:	Nemko, DNV
USA	:	FCC, NVLAP
Japan	:	VCCI

The related certificate for our laboratories about the test site and management system can be downloaded from Quietek Corporation's Web Site :<http://tw.quietek.com/modules/enterprise/services.php?item=100>
The address and introduction of Quietek Corporation's laboratories can be founded in our Web site :
<http://www.quietek.com/>

If you have any comments, Please don't hesitate to contact us. Our contact information is as below:

HsinChu Testing Laboratory :

No.75-2, 3rd Lin, Wangye Keng, Yonghxing Tsuen, Qionglin Shiang, Hsinchu County 307, Taiwan, R.O.C.

TEL:+886-3-592-8858 / FAX:+886-3-592-8859

E-Mail : service@quietek.com



LinKou Testing Laboratory :

No. 5, Ruei-Shu Valley, Ruei-Ping Tsuen, Lin-Kou Shiang, Taipei, Taiwan, R.O.C.

TEL : 886-2-8601-3788 / FAX : 886-2-8601-3789

E-Mail : service@quietek.com



Reports from Both Laboratories Are Accepted by :

