

DELTA AS300/DVP-ES3 MODBUS TCP/IP

Supported Series: DELTA AS300 / DVP-ES3

Website: <http://www.deltadrivers.com>

HMI Setting:

Parameters	Recommended	Options	Notes
PLC type	DELTA AS300/DVP-ES3 MODBUS TCP/IP		
PLC I/F	Ethernet		
Port no.	502		
PLC sta. no.	1		

Device Address:

Bit/Word	Device type	Format	Range	Memo
B	X_Bit	DDdd	0 ~ 6315	
B	Y_Bit	DDdd	0 ~ 6315	
B	X_Bit (Oct)	OOO	0 ~ 377	
B	Y_Bit (Oct)	OOO	0 ~ 377	
B	M	DDDD	0 ~ 8191	
B	SM	DDDD	0 ~ 4095	
B	S	DDDD	0 ~ 2047	
B	T_Flag	DDD	0 ~ 511	
B	C_Flag	DDD	0 ~ 511	
B	HC_Flag	DDD	0 ~ 255	
B	D_Bit	DDDDDDdd	0 ~ 2999915	
B	L_Bit	DDDDDD	0 ~ 131071	
W	X	DD	0 ~ 63	
W	Y	DD	0 ~ 63	
W	SR	DDDD	0 ~ 2047	
W	D	DDDDDD	0 ~ 29999	
W	T	DDD	0 ~ 511	
W	C	DDD	0 ~ 511	
DW	HC	DDD	0 ~ 255	
W	E	D	0 ~ 9	
W	L	DDDDDD	0 ~ 131071	
W	X (Oct)	OO	0 ~ 17	

Bit/Word	Device type	Format	Range	Memo
W	Y (Oct)	OO	0 ~ 17	

Wiring Diagram:

Ethernet cable:

