

YASKAWA MP Series - Memobus

Supported Series: YASKAWA MP2200, MP2300, MP2300S, MP9xx communication module.

Website: <http://www.yaskawa.com/>

HMI Setting:


Parameters	Recommended	Options	Notes
PLC type	YASKAWA MP Series - Memobus		
PLC I/F	RS485/Ethernet	RS232/RS485 2w/4w, Ethernet	
Baud rate	19200	9600~57600	
Data bits	8		
Parity	Even		
Stop bits	1		
Port no.	502	default	Ethernet Module Only
PLC sta. no.	1	1-31	

PLC Setting:

Communication mode	MEMOBUS, Slave, RTU
---------------------------	---------------------

PLC Ethernet Setting:

1. Use MPE720 program software, open Module Configuration, double click "218IFA".



- In Transmission Parameters input MP2300S IP address, Subnet Mask, Gateway IP. In Connection Parameter, CNO -1 input: Local Port=502, Node IP address=000.000.000.000, Node Port=00000, Connect Type=TCP, Protocol Type=MEMOBUS, Code=RTU.

Parameters : IP2 : 168 : 1 : 1 (0-255) Module Name Definition
 Equipment name : CONTROLLER B
 : 255 : 255 : 255 : 0 (0-255)
 Address : 0 : 0 : 0 : 0 (0-255) Detail Definition

It is possible to following parameter setting easily that communicate the message.

Local Port	Node IP Address	Node Port	Connect Type	Protocol Type	Code
00502	000.000.000.000	00000	TCP	MEMOBUS	RTU

It is possible to set easily that communicate the I/O message.


Input/Output : Low Scan

Local Port	Node IP Address	Node Port	Connect Type	Protocol Type	Code

Head register number data size Head register number data size

input disable	IW0000	4	W <-	Hold register(MW)	00000	4	W	Node eq
output disable	OW0004	4	W ->	Hold register(MW)	00004	4	W	

- Click MECHATROLINK to set up MP2300S PLC as Master.



- Close all dialogs and save to MP2300S.

Note:

1. Only CNO 01 can auto communicate with one HMI. Other CNO need a ladder program created for communication.
2. DIP SW2-2 of MP2300S must be set to OFF position during normal communication, otherwise, IP address will be erased after reset power, and it will be unable to communicate with HMI when set to ON position.

Device Address:

Bit/Word	Device type	Format	Range	Memo
B	MB_1	DDDDh	0 ~ 9999f	MB 0 ~ 9999
B	MB_2	DDDDh	100000 ~ 65534f	MB 10000 ~ 65535
B	IB	HHHHH	0 ~ a7ff0	Read only
B	IW_Bit	HHHHdd	0~ a7ff15	
W	IW	HHHH	0 ~ a7ff	Read only
DW	IL	HHHH	0 ~ a7ff	Read only
DW (F)	IF	HHHH	0 ~ a7ff	Read only
W	MW	DDDDD	0~ 65534	Holding register
DW	ML	DDDDD	0 ~ 65533	Double word
DW (F)	MF	DDDDD	0 ~ 65533	Floating point

*: When connect via Ethernet interface the max range of IW, IL and IF would be restricted.

Wiring Diagram:

Diagram 1

RS-232

The serial port pin assignments may vary between HMI models, please click the following link for more information.




Diagram 2

RS-485 2W

The serial port pin assignments may vary between HMI models, please click the following link for more information.




Diagram 3

RS-485 4W

The serial port pin assignments may vary between HMI models, please click the following link for more information.




Diagram 4

Ethernet cable:

