

DL/T645-2007 Standard

Website: <http://www.cw180.com>

HMI Setting:

Parameters	Recommended	Options	Notes
PLC type	DL/T645-2007 Standard		
PLC I/F	RS485 2W		
Baud rate	9600		
Data bits	8		
Parity	Even		
Stop bits	1		
PLC sta. no.	1		

PLC Setting:

DL/T645-2007多功能表通信协议

功能 操作 端口 其他

通讯地址: 201412110001 密码: 00000000 操作员代码: C0C1C2C3

数据标识	数据项名称	数据	单位	数据格式
04000103	最大需量周期	15分	分	NN
04000104	滑差时间	10分		

修改

电能量
最大需量及发生时间
变量
参变量
日期及星期时间
基本参数
表常数表号版本
每月结算日
第一套第1时段表数据
第一套第2时段表数据
第一套第3时段表数据
第一套第4时段表数据

通讯端口设置

通讯端口: COM 1 超时(秒): 1.0

波特率: 2400 通讯延时(毫秒): 0

数据位: 8 Bits 使用者: 0

校验: Even 密码: 0

停止位: 1 Bit 电表地址: 201412110001

确定 取消

System Tag:

LW-10700 (4 words)	DLT_645 operator (COM 1)
LW-10704 (4 words)	DLT_645 password (COM 1)
LW-10708 (6 words)	DLT_645 address (COM 1)
LW-10715 (4 words)	DLT_645 operator (COM 2)
LW-10719 (4 words)	DLT_645 password (COM 2)
LW-10723 (6 words)	DLT_645 address (COM 2)
LW-10730 (4 words)	DLT_645 operator (COM 3)
LW-10734 (4 words)	DLT_645 password (COM 3)
LW-10738 (6 words)	DLT_645 address (COM 3)

Device Address:

Bit/Word	Device type	Format	Range	Memo
W	Data	HHHHHHHH	0 ~ 6FFFFFFF	

Wiring Diagram:

RS-485 2W

The serial port pin assignments may vary between HMI models, please click the following link for more information.

