

Siemens S7-1200 (Symbolic Addressing)

(Ethernet)

Supported Series: Siemens S7-1200 series Ethernet.

Website: <http://www.siemens.com/entry/cc/en/>


HMI Setting:

Parameters	Recommended	Options	Notes
PLC type	Siemens S7-1200 (Symbolic Addressing) (Ethernet)		
PLC I/F	Ethernet		
Port no.	102		
Rack	0		
CPU slot	1		

On-line simulator	Yes	Multi-HMI connect	TIA Settings *Note
-------------------	-----	-------------------	--------------------

*Note:

According to Connection resource / HMI Communication settings




The screenshot shows the 'Connection resources' table in the Siemens TIA Portal. The table is divided into 'Station resources' and 'Module resources'. The 'Station resources' section includes 'Reserved' and 'Dynamic' columns. The 'Module resources' section includes 'PLC_1 [CPU 1515-2 PN]' and 'Configured' columns. The 'HMI communication' row is highlighted with a red arrow, showing 4 reserved resources and 0 configured resources. The 'Connection resources' tab in the left sidebar is also highlighted with a red arrow.

	Station resources		Dynamic	Module resources
	Reserved	Configured		
Maximum number of resources:	10		98	108
PG communication:	4	-	-	-
HMI communication:	4	0	0	0
S7 communication:	0	-	0	0
Open user communication:	0	-	0	0
Web communication:	2	-	-	-
Other communication:	-	-	0	0
Total resources used:	0	0	0	0
Available resources:	10		98	108

PLC Setting:


1. In S7-1200 program software create PLC program and tag and then download to PLC.
2. Select Go offline, EasyBuilder will connect to PLC and get tag data. In PLC type select “SIEMENS S7-1200 (Ethernet)”.



The **Device Properties** dialog box is shown with the following settings:

- Name: Siemens S7-1200 (Ethernet)
- Radio buttons: ☐ HMI, ☒ PLC
- Location: Local (dropdown menu), with a **Settings...** button next to it.
- PLC type: Siemens S7-1200 (Ethernet) (dropdown menu)
- Path: V.1.80, SIEMENS_S7_1200.so
- PLC I/F: Ethernet (dropdown menu)
- IP: 192.168.1.95, Port=102, with a **Settings...** button next to it.
- ☐ Use UDP (User Datagram Protocol)
- PLC default station no.: 2
- Buttons: **OK** and **Cancel**


3. Click “Settings...”, input PLC IP address.






The **IP Address Settings** dialog box is shown with the following settings:

- IP address: 192 . 168 . 0 . 95
- Port no.: 102
- Timeout (sec): 1.0 (dropdown menu)
- Turn around delay (ms): 0
- Send ACK delay (ms): 0
- Parameter 1: 0
- Parameter 2: 0
- Parameter 3: 0
- Buttons: **OK** and **Cancel**


4. Check the PLC that is not connected to any PC. Click “Get tag info...”.
5. Supported by firmware V3.X and previous versions. For V4.0 or later, please see **How to Connect With S7-1200 Firmware V4.0**




6. If the software used is a version later than TIA Portal V11 , SP2, a dialog of FunctionBlock directory will be shown, users have to define the mapping from FB to DB in this directory then click “Check OK” . The tag information will be gained and a successful message is shown.




7. When opening an existing project and get the tag information again, if the PLC software used is TIA Portal V12 and later versions, the DB name must be entered again in order to compile the project.




8. Added Tag Manager that allows selecting the Siemens S7-1200 PLC tags to be imported.




9. Create an object and click read address "Setting..."



10. In PLC name select S7-1200 then click Tag.




11. Select PLC tag.




How to Connect With S7-1200 Firmware V4.0

There are certain restrictions in S7-1200 firmware V4.0, therefore, to avoid communication errors, please follow the steps to set up. (EasyBuilder8000 does not support Siemens S7-1200 firmware V4.0 and later versions).

Right click on the PLC program, and then click **[Properties]**.




Select **[Protection]**, and then select **[Permit access with PUT/GET communication from remote partner (PLC,HMI,OPC,...)]**.




The following part introduces how to export S7-1200 PLC Tags and Program Blocks.

Exporting PLC Tags (I,Q,M tags)


1. Under **[PLC tags]** select **[Show all tags]**.



2. Click **[Export]** to export the tags.




3. Browse for the directory to save the exported file and then click **[OK]**.




Exporting Program Blocks(DB)


- When the database contains Struct data type, please note the following restrictions.
Please at least add one data member that doesn't belong to Struct data type into DB, otherwise, the data cannot be imported to EasyBuilder.
Multidimensional Arrays and Multilayer Structs are not supported.
After building DB, please do the following actions for Struct address:
 - (1) Copy the complete Struct data.
 - (2) Delete data.
 - (3) Add a new row.
 - (4) Paste data.



- Right click on DB, click **[Generate source from blocks]**, and then enter the file name to save.




After building and importing PLC Tags and Program Blocks, click **[Download to device]**.




Importing PLC Tags and Program Blocks(DB)

1. Launch EasyBuilder and set the IP address.




2. Click **[Import Tag...]**.




3. Select the PLC Tags and Program Blocks to be imported. Please remember to change DB number, and select **[Use S7-1200 firmware version 4.0 or later versions]**. Click **[Import]** to import the files. The I, Q, and M addresses will be checked, if an error occurs, the communication will fail. If this happens, please check your communication environment, and try to import again.


*** At least one db file must be imported. If only plc tags cannot be imported successfully.**




4. The "Import status" field will display the result, click **[OK]**.



5. Select the tags to be imported and then click **[OK]**.



6. The following message is displayed when the import has succeed.



Support Device Type:

Data type	EasyBuilder data format	Memo
Bool	bit	
Byte	16-bit BCD, Hex, Binary, Unsigned	8-bit
SInt	16-bit BCD, Hex, Binary, Signed	8-bit
USInt	16-bit BCD, Hex, Binary, Unsigned	8-bit
Word	16-bit BCD, Hex, Binary, Unsigned	16-bit
Int	16-bit BCD, Hex, Binary, Signed	16-bit
UInt	16-bit BCD, Hex, Binary, Unsigned	16-bit
DWord	32-bit BCD, Hex, Binary, Unsigned	32-bit
DInt	32-bit BCD, Hex, Binary, Signed	32-bit
Real	32-bit Float	32-bit
UDInt	32-bit BCD, Hex, Binary, Unsigned	32-bit
LInt	64-bit Signed	64-bit
ULInt	64-bit Unsigned	64-bit
LWord	64-bit Unsigned	64-bit
Double	64-bit Float	64-bit
Char	16-bit BCD, Hex, Binary, Unsigned	USInt
CREF		Struct
Date	16-bit BCD, Hex, Binary, Unsigned	UInt
DTL		Read only
ErrorStruct		
IEC_COUNTER		
IEC_DCOUNTER		
IEC_SCOUNTER		
IEC_TIMER		
IEC_UCOUNTER		
IEC_UDCOUNTER		
IEC_USCOUNTER		
NREF		

Data type	EasyBuilder data format	Memo
Time	32-bit BCD, Hex, Binary, Unsigned	DWord
Time_Of_Day	32-bit BCD, Hex, Binary, Unsigned	DWord
Array		Bool, Byte, SINT, USInt, Word, Int, UInt, DWord, Dint, Real, UInt
Struct		Bool, Byte, SINT, USInt, Word, Int, UInt, DWord, Dint, Real, UInt

Note1: EBPro V6.03.02 or later supports 64 bits data type (**cMT Series only**), but please note that the address limit range is 48 bits in maximum.

Note2: Importing data types other than those in the above table may result in failure to communicate.

Wiring Diagram:

Ethernet cable:

