

# IEC 61850 MMS Server

## HMI Setting:

Parameters	Recommended	Options	Notes
PLC type	IEC 61850 MMS Server		
PLC I/F	Ethernet		
Port no.	102		

## Import Tags:

**[Import File]:** SCL files (\*.icd, \*.cid)

**[Supported data types]:** Boolean, Float32, Float64, Enum, Int8, Int16, Int32, Int64, Int128, Int8U, Int16U, Int24U, Int32U, Quality, Timestamp, VisibleString32, VisibleString64, VisibleString65, VisibleString129, VisibleString255, OctetString6, OctetString8, OctetString64, CodedEnum, Check

Device list:

[What's my IP?](#)

	Name	Location	Device Type	Interface	I/F Protocol	Sta
Local HMI	Local HMI	Local	cMT3092X (1024 x 768)	-	-	0
Local Device 4	IEC 61850 MMS Server	Local	IEC 61850 MMS Server	Ethernet(Port = 102)	TCP/IP	N/A

New HMI...

New Device/Server...

Delete

Settings...

Import Tags...

## Wiring Diagram:

### Ethernet cable:

